

EXCAVATE / FILL & PROVIDE 100 mm TOPSOIL AND SEED AS REQUIRED TO MATCH INTO EXISTING SURFACE AT A SPECIFIED GRADE. MINIMUM GRADE OF 1:5. MAXIMUM GRADE TO BE 1:1 TO PREVENT ANY DAMAGE TO MATURE AGE TREES


MINIMUM VERGE OF 500mm. VERGE WIDTH CAN BE REDUCED TO PREVENT ANY DAMAGE TO MATURE AGE TREES.

ALL ORGANIC & UNSUITABLE MATERIAL SHALL BE REMOVED TO A FIRM NATURAL SUBGRADE & THE AREA BACKFILLED WITH CRUSHED ROCK (20 mm CLASS 2) TO THE UNDERSIDE OF THE CONCRETE. MINIMUM 50 mm TO BE PROVIDED.

NOTES
1. ALL JOINTS TO BE SAWCUT.

CITY OF MONASH

TYPICAL SHARED PATHWAY CROSS SECTION (3.0m)

DIRECTOR INFRASTRUCTURE: 		
DRAWN: M. K. March 2013	SCALE: N.T.S.	SHEET: C12
DWG NAME: STDWG C12	21500	REV: A JUN15