



NOTES:

1. REFER TO SHEET D1 & D3 FOR STANDARD PIT DIMENSIONS & FOR FRAME LID & LINTEL DETAILS.
2. FOR PITS DEEPER THAN 1.0 m STEP IRONS AT 300 mm CENTRES SHALL BE INSTALLED (FIRST STEP IRON AT 450 mm FROM PIT FLOOR).
3. PITS OVER 1.5 m TO BE CORBELLED TO SUIT STANDARD FRAME & LID.
4. ALL CONCRETE TO BE N32 STRENGTH GRADE.
5. THE PIT FLOOR TO BE POURED PRIOR TO CONSTRUCTING THE WALLS.

ESTIMATED POINT LOAD CAPACITIES

PIT LID	LINTEL	FRAME
950kg	3200kg	1950kg

CITY OF MONASH

DIRECTOR INFRASTRUCTURE SERVICES:

Peter Stumann

SIDE ENTRY PIT

DRAWN:
W.Du March 2003

SCALE: 1:20

SHEET:

DWG NAME:
STDWG D02

21500

D 02