


- NOTES:
1. ALL CONCRETE TO BE CLASS 25MPa.
 2. ALL FILLET WELDS TO BE 6mm CONTINUOUS.
 3. ALL STEEL TO BE FABRICATED WITH GALVANISED STEEL AND COATED WITH DULUX LUXATHANE 'WOODLAND GREY', TWO PACK EPOXY SPRAYED FINISH AS APPROVED BY THE SUPERINTENDENT.
 4. ROUND PIPE POST CAPS SHALL BE SPOT WELDED AT TWO LOCATIONS.
 5. TYPICAL POST FOOTING APPLIES TO GATE SUPPORTS & OPEN SUPPORT POSTS - QTY. 3

CITY OF MONASH 

STEEL GATE

DIRECTOR INFRASTRUCTURE: 		
DRAWN: ARI. T JUNE 2009	SCALE: N.T.S.	SHEET: M 04
DWG NAME: STDWG M04	21500	REVA: JUN15